

RECONCILING A SIMULATION MODEL WITH MEASUREMENTS

Didier Thevenard & Emily Cooke

May 2018

Objective

- **Starting point: as-built PVsyst model**
 - Typically used in financial model
 - Has two major components:
 - ❖ The climate file (with horizontal irradiance)
 - ❖ The plant model itself
- **The question: do operational data agree with the plant model?**
 - The original model is run with actual weather data
 - Some parameters are adjusted until the simulation agrees with measured data
- **Method**
 - Canadian Solar's own simulation tool, CASSYS, is used
 - Freeware and open-source: <http://canadiansolar.github.io/CASSYS/>
 - Program was developed first and foremost for use in Operations
 - Inputs and underlying model are very similar to PVsyst
 - ❖ Some alternate models are available
 - ❖ Can be run with any time step and in batch mode

Test dataset and original PVsyst model

The test dataset



- Site in Eastern Ontario
- 10 MWac, 14 MWdc
- 13 x 769 kW SMA inverters
- 46,656 Canadian Solar CS6X panels
- Fixed orientation (28° facing South)
- Data averaged and recorded every **5 minutes**
- **Year 2** of operation is used

The original PVsyst model

- Heat loss factor: 29 W/m²·K
- DC losses: 1.5% at STC
- AC losses: 1.5% at STC
- Transformer losses: 0.3% iron loss, 1.6% resistive/inductive loss
- Other losses: Quality: 1.6%, Mismatch: 1%, Soiling: 0.5%
- Hourly data

Instrumentation and Data Collection


Weather Station



Inverter

Recombiner

Combiner




Revenue Check Meter




Data cleaning

Periods with events are removed to obtain a clean dataset





The unadjusted simulation



MBE = -0.48%
RMSE = 6.5%

The unadjusted simulation (cont'd)



Step-by-step adjustment

Step 1: POA irradiance calculation

Step 2: DC side


Step 3: Inverter

Step 4: AC side

Step 5: Effect of averaging period

Conclusion

POA irradiance



MBE = 0.83%
RMSE = 7.8%

Step-by-step adjustment

Step 1: POA irradiance calculation

Step 2: DC side


Step 3: Inverter

Step 4: AC side


Step 5: Effect of averaging period

Conclusion

Panel temperature




Heat loss factor = 29 W/m²/K
MBE = 0.3 °C
RMSE = 2.8 °C



Heat loss factor = 29.9 W/m²/K
MBE = 0.0 °C
RMSE = 2.8 °C


DC calculations – clear day, non clipping

average inverter DC input (kW)




Quality loss = 1.6%, mismatch loss = 1%
MBE = -2.5%
RMSE = 4.7%

average inverter DC input (kW)



Quality loss = -1.3%, mismatch loss = 0%
MBE = 0%
RMSE = 3.2%

'Spectral' correction



Step-by-step adjustment

Step 1: POA irradiance calculation

Step 2: DC side


Step 3: Inverter

Step 4: AC side

Step 5: Effect of averaging period

Conclusion

Inverter



Step-by-step adjustment

Step 1: POA irradiance calculation

Step 2: DC side

Step 3: Inverter

Step 4: AC side

Step 5: Effect of averaging period

Conclusion


AC side – Transformer Info

- Transformer test data is available from as-built documentation
- Provides no-load loss and full-load loss


PERFORMANCE DATA			
Test Title	Result	Test Title	Result
Core Loss (watts)	1282 @ 85 deg. C	IX (%):	4.06
Winding Loss (watts)	13814 @ 85 deg. C	IR (%):	0.86
Total Loss (watts)	15096	X / R Ratio	4.72
Efficiency @ 25%:	99.46%	System Impedance (%):	4.15
Efficiency @ 50%:	99.41	Impedance (%) HL1:	4.41
Efficiency @ 100%:	99.06		

- Values can be entered directly into CASSYS
 - No-load loss **15.6 kW**
 - Total loss **132.1 kW**

AC side



AC wiring losses = 0.5%



AC wiring losses = 1.8%

Step-by-step adjustment

Step 1: POA irradiance calculation

Step 2: DC side


Step 3: Inverter

Step 4: AC side


Step 5: Effect of averaging period

Conclusion

Effect of averaging period



Effect of averaging period (cont'd)



Step-by-step adjustment

Step 1: POA irradiance calculation

Step 2: DC side


Step 3: Inverter

Step 4: AC side

Step 5: Effect of averaging period

Conclusion

The adjusted simulation



MBE = 0%
RMSE = 5%

Conclusions

Adjustment procedure

- Enables to match simulation results to actual data
- Creates model that can be used for operational purposes

Don't trust inverter data

- Even when averaging across all inverters, inaccuracy is high
- Resulting adjusted parameters are physically questionable
- Adjusting without using inverter data may actually lead to better results

Major takeaways from this exercise

- System efficiency varies significantly with clearness index (+1.5%)
- Use of hourly data leads to overestimation of output (-1.5%)

QUESTIONS AND COMMENTS ARE WELCOME!

Didier Thevenard

Senior Manager, Operations and Analytics

Canadian Solar O&M, Module & System Solutions

P: +1 519-837-1881 x2340 | M: +1 519-546-4038

didier.thevenard@canadiansolar.com

HQ – Canada

545 Speedvale Avenue West, Guelph, Ontario. Canada N1K 1E6

P: +1 519 837 1881 | F: +1 519 837 2550

E: sales.ca@canadiansolar.com

United States

3000 Oak Road, Suite 400, Walnut Creek, California, USA 94583

P: + 1 925 807 7503 | F: + 1 925 866 2704

E: sales.us@canadiansolar.com