




# XCEL ENERGY PV+BATTERY PILOT PROJECTS

# INNOVATIVE CLEAN TECHNOLOGY (ICT) PROJECTS



**2009**  
**Colorado Solar Integration Project**  
 (Grand Junction, Colorado)



Parabolic trough solar plant with turbine capacity 2 MW

**2012**  
**Community Energy Storage Project**  
 (Aurora, Colorado)



- 25kW/50kWh Sodium-Nickel-Chloride BESS
- $\Sigma$ PV = 19.5 kW

**2015**  
**Panasonic Project**  
 (Denver)



- 1MW/2MWh Li-Ion BESS
- $\Sigma$ PV = 1.5MW
- Microgrid

**2015**  
**Stapleton Project**  
 (Denver)



- Six utility-sited BESS
- Six BTM BESS
- High PV feeder

# PANASONIC PROJECT

# PEÑA STATION/PANASONIC PROJECT



→ To Xcel Energy Grid

3.376 kVA PV on feeder



Denver International Airport Parking Lot at 61st and Peña Rail Stop  
1.6 MWdc Carport Solar PV System



S&C Electric Company  
Islanding Switch



Panasonic Technology & Business Solutions Center  
Anchor Load plus 259 kWdc Rooftop Solar PV System



Xcel Energy  
Transformer



Yunicos Y.Cubes  
1 MW / 2 MWh Battery Energy Storage System

## Project Partners

**Panasonic**



**Yunicos**



# PANASONIC PROJECT OBJECTIVES




- Microgrid/Islanding of Panasonic building
- Peak Demand Reduction
- Energy Arbitrage
- Frequency Response
- Voltage Regulation
- PV smoothing/Ramp Rate Limiting

# PANASONIC PROJECT RAMP RATE ON 8/21/17 ECLIPSE




## Eclipse 08/21/2017 Panasonic Project




# PV "SMOOTHED" OUTPUT 8/21/17



## 08/21/2017 "Smoothed" Power Output




# PV & PRIMARY VOLTAGE NO RAMP RATE LIMITING



# PV & PRIMARY VOLTAGE WITH RAMP RATE LIMITING




## PV and Primary Voltage April 18




# PV RAMP RATE LIMITING

## PV Ramp Rate Limiting Apr 18



# VOLT-VAR CURVE




## Example Volt-VAR

- Nominal voltage = 13.2kV, i.e. voltage at the transformer primary
- Deadband =  $\pm 2.5\%$  of nominal voltage
- $V_{min} = 0.8 V_{nominal}$
- $V_{max} = 1.2 V_{nominal}$


# OVERVOLTAGE ON PRIMARY 4/17-4/24




## 3Phase Voltage 4/17



# VOLT-VAR BY BESS 4/17-4/24




# EXPECTED VS ACTUAL OUTPUT



# STAPLETON PROJECT

# STAPLETON NEIGHBORHOOD



- Stapleton feeder has ~18.5% PV penetration (2017)
- Utility-Sited Systems:
  - Six Li-Ion battery energy storage systems
  - Sited along the feeder at two different phases
- Behind-the-Meter Systems:
  - Six Li-Ion battery energy storage systems
  - Sited in a customer's home

# STAPLETON UTILITY SITED OVERVIEW



## Northern Reliability Modular Units:

- 2 x 18 kW/69 kWh
- 2 x 36 kW/138 kWh
- 2 x 54 kW/207 kWh

## Objectives/Use Cases:

- Peak Demand Reduction
- Voltage Regulation
- Solar Time Shifting
- Energy Arbitrage


# STAPLETON BEHIND-THE-METER OVERVIEW




- **Sunverge SIS units**
  - 6 x 6 kW/15.5 kWh
- **Objectives/Use Cases:**
  - Providing Residential Backup Power
  - Peak Demand Reduction
  - Solar Time Shifting
  - Volt-Watt Operation (?)




# CHARGING FROM PV AT HIGH VOLTAGE



# CHARGING FROM PV AT HIGH VOLTAGE




# SAMPLE TEST SOLAR TIME SHIFTING



# TEST SAMPLE RESULTS

## Test Results for BTM Unit



Thank you

# UPDATES & SUMMARY



- Environmental controls
  - Panasonic: Multiple cold-temperature alarms. Solution: Use the inverters to output reactive power (~50 kVAR) to ensure heating stays on.
  - Sunverge: Cold temperatures kicks the units into self-preservation mode, disrupting schedule. Solution: Sunverge has updated the control logic to allow heaters to come on at specific times.
- Lack of standardization across vendor platforms
  - Control algorithm for the modes of operation
  - Communication protocol (all support DNP3 but Xcel is connecting to all the systems in different ways)
- Lessons Learnt:
  - Make sure data is captured consistently (scaling factors, polling time, latency etc)
  - Make sure vendor understands specific operation/mode/use case

# Communications / Control



- Treated site as a substation
- Fiber to site with multiple security zones
- 2 RTU's
  - One for SCADA
  - One for DNP3 to Modbus
- Battery control is through vendor UI
- Islanding control utilizes SCADA
- Stapleton will be controlled through SCADA (no vendor UI)



# YOUNICOS ENERGY STORAGE PARAMETERS



Description	Value
Rated Apparent Power	1,000 kVA
Rated Real Power	1,000 kW
Rated Energy	2,100 kWh
Available Energy	1,690 kWh
Round-Trip Efficiency	85.5 %
Voltage Range	432-528 V
Rated Continuous AC Current	1,200 A
Operating Temp. Range	-10°C - 45°C
Physical Dimension	42' x 10'



# NRI ENERGY STORAGE PARAMETERS



Description	18 kW System	36 kW System	54 kW System
Rated Apparent Power	18 kVA	36 kVA	54 kVA
Rated Real Power	18 kW	36 kW	54 kW
Rated Energy	69 kWh	138 kWh	207 kWh
Round-Trip Efficiency	N/A		
Voltage Range	172 – 264 V		
Rated Continuous AC Current	94 A	187 A	281 A
Operating Temp. Range	-30°C -50°C		
Physical Dimension	56" x 52.75" x 53"	112" x 52.75" x 53"	159" x 52.75" x 53"

# SUNVERGE SIS UNIT



Hybrid Inverter  
(4.5kW or 6kW rated)

IO Board

Solar Charge Controller  
(150V or 600V MPPT)

Distribution Panel

Application Gateway

Outdoor rated cabinet

Lithium-ion Battery  
(Scaleable to 19.4 kWh)

Polycrete pad

# SUNVERGE ENERGY STORAGE PARAMETERS




Description	Value
Rated Apparent Power	6 kVA
Rated Real Power	6 kW
Rated Energy	15.5 kWh
Available Energy	11.64 kWh
Round-Trip Efficiency	92.5 %
Voltage Range	233 – 247 V
Rated Continuous AC Current	25 A
Operating Temp. Range	-20°C - 50°C
Physical Dimension	76" x 34" x 14 "

# SUNVERGE ONE LINE



## SUNVERGE "BACK COUPLED" AC SIS SINGLE LINE DIAGRAM



CONFIDENTIAL

- ① SUNVERGE AC SOLAR INTEGRATION SYSTEM (SIS).
- ② NOT ALWAYS REQUIRED, CONSULT LOCAL CODE AND AHJ.
- ③ NOT INCLUDED WITH SIS UNIT.
- ④ MUST BE POWERED BY CLP.
- ⑤ HARDWIRED CONNECTION TO INTERNET.
- ⑥ NEW PANEL (OPTIONAL).
- ⑦ 50A CIRCUIT BREAKER.
- ⑧ TOTAL LOAD CANNOT EXCEED RATING OF SIS INVERTER.
- ⑨ 15A CIRCUIT BREAKER FOR VOLTAGE REFERENCE.
- ⑩ SPLIT-CORE AC CURRENT SENSOR.
- ⑪ MUST NOT EXCEED 200A.
- ⑫ NO = NORMALLY OPEN; NC = NORMALLY CLOSED.
- ⑬ MAX CAPACITY 6KW.
- ⑭ OPTIONAL 3/4G MODEM FOR INTERNET CONNECTION.